WORCESTER TOWNSHIP 1721 VALLEY FORGE ROAD PO BOX 767 WORCESTER PA 19490-0767 PHONE (610) 584-1410 FAX (610) 584-8901

NOTICE

TO: Gas line installers of swimming pools, generators or other outdoor appliances

SUBJECT: Maximum Gas Demand

When <u>any</u> natural gas appliance, (including pool heaters or generators) are installed in Worcester Township, it shall be the responsibility of the gas line installer to insure compliance with Section G2413 of the 2009 International Residential Code (IRC) or Section 402 of the 2009 International Fuel Gas Code (IFGC).

In addition to their completed building permit application, the professional installer shall provide a <u>signed</u> <u>letter</u>, written on their company letterhead, indicating they have preformed the proper fuel load calculations and have met the requirements of Section G2413 of the IRC or Section 402 of the IFGC.

Russ Davis Keystone Municipal Services, Inc. Worcester Township Building Inspector/Plan Examiner